

September 17, 2014

BID #1383

BID PACKAGE  
FOR  
REHABILITATION/RECONSTRUCTION WORK TO  
SCHMID RESIDENCE  
54 MILFORD POINT ROAD  
MILFORD, CONNECTICUT

ENGINEERS: DIVERSIFIED TECHNOLOGY CONSULTANTS

**ADDENDUM NO. 1**

THE FOLLOWING SHALL BE INCORPORATED INTO THE WORK.

1. Clarification of scope; 2<sup>nd</sup> Floor gypsum wall board (GWB) replacement:
  - a. Specified work includes replacing moisture damaged GWB on the 2<sup>nd</sup> Floor. What is the extent of the GWB replacement?

Response:

1. Base bid shall include removal and replacement of all 2<sup>nd</sup> Floor GWB.

THE BID DATE AND TIME IS NOT CHANGED BY THIS ADDENDUM

CONTRACTORS SHALL ACKNOWLEDGE THIS ADDENDUM ON THE BID FORM

END OF ADDENDUM NO. 1.